




## CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
<b>TEST REPORT NUMBER</b> 'Assessment Reports' are not acceptable	2180577.53	<b>CERTIFICATE NUMBER</b>	2194106.04rev-UAE
<b>DATE OF ISSUE</b>	13 August 2015	<b>DATE OF ISSUE</b>	05 August 2016
<b>DATE OF EXPIRY</b>	By expiration of the standard(s)	<b>DATE OF EXPIRY</b>	+ 2 years from date of issue
Manufacturer details			
<b>NAME OF FACTORY/ MANUFACTURER</b>	SC Cooper Industries Romania SRL	<b>NAME OF THE BRAND</b>	EATON
<b>FACTORY ADDRESS / REGION</b> (STREET / TOWN / CITY / COUNTRY )	Zona Industriala Vest 310510 Arad Romania	<b>MODEL / NO</b>	GuideLed 108xx CGLine+ GuideLed 118xx CGLine+
<b>WEBSITE</b>	www.ceag.de	<b>LOGO ON THE PRODUCT</b>	
<b>TEL</b>	+49 292 169 870	<b>EMAIL</b>	Info-n@ceag.de



2194106.04rev-UAE

Product Details From Test Report		Reference Test Report page NO
<b>DESCRIPTION OF THE PRODUCT</b> (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Luminaire for emergency lighting with LED light source	2
<b>TEST STANDARD</b> (SUCH AS ASTM/BS EN/ DN ETC)	Full type testing according to EN/IEC 60598-2-22	3
<b>TEST DESCRIPTION</b>	Full examination according to the above mentioned Test Standard(s).	3-64
<b>SPECIFICATION OF TEST SPECIMEN</b>	All tests conducted on model: GuideLED 10812 CGLine+ which is representative for the entire series.	3-64
<b>TEST RESULT</b> (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/OBSERVATION ___/ETC)	All applicable clauses as mentioned in the Test Report have passed the test.	3-64
<b>PRODUCT APPLICATION GUIDELINE (END USE)</b> (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	For installation in Self-contained Emergency Lighting Systems with automatic test functions and may include service for connection to centrally monitored systems via bus connection. Equipped with sufficient battery capacity for 3 h emergency lighting duration.	



2194106.04rev-UAE

<b>Laboratory and Certification body details</b>			
<b>NAME OF CERTIFICATION BODY</b>	DEKRA Certification B.V.	<b>NAME OF TEST FACILITY</b>	DEKRA Certification B.V.
<b>CERTIFICATION BODY ADDRESS / REGION</b> <small>(STREET / TOWN / CITY / COUNTRY )</small>	Meander 1051 6825 MJ Arnhem The Netherlands	<b>TEST FACILITY ADDRESS / REGION</b> <small>(STREET / TOWN / CITY / COUNTRY )</small>	Meander 1051 6825 MJ Arnhem The Netherlands
<b>WEBSITE</b>	www.dekra-certification.com	<b>WEBSITE</b>	www.dekra-certification.com
<b>TEL</b>	+31 88 96 83000	<b>TEL</b>	+31 88 96 83000
<b>EMAIL</b>	lighting@dekra.com	<b>EMAIL</b>	lighting@dekra.com
<b>ACCREDITED BY</b> <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	Dutch Accreditation Council RVA  www.rva.nl	<b>ACCREDITED BY</b> <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	Dutch Accreditation Council RVA  www.rva.nl
<b>AS PER</b> <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	ISO/IEC 17065	<b>AS PER</b> <small>(STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)</small>	ISO/IEC 17065 ISO/IEC 17025
<b>VALIDITY</b> <small>(EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)</small>	1 May 2018	<b>VALIDITY</b> <small>(EXPIRY DATE OF LABORATORY ACCREDITATION)</small>	1 May 2018 1 March 2018
<b>REFERENCE NUMBER:</b> <small>(CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	C001	<b>REFERENCE NUMBER:</b> <small>(THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	C001 L022
<b>CERTIFICATION MARK</b>	ENEC and KEMA-KEUR		



2194106.04rev-UAE

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	J.G. van Bekkum	SIGNATURE	
EMAIL / TEL	HansvanBekkum@Eaton.com +31 631 774 776	FACTORY OFFICIAL SEAL	<b>CEAG</b> <b>Notlichtsysteme GmbH</b> <b>Senator-Schwartz-Platz 2</b> <b>59494 Soest</b>
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	drs G.J. Zoetbrood	SIGNATURE	
EMAIL / TEL	lighting@dekra.com +31 88 96 83000	CERTIFICATION BODY OFFICIAL SEAL	<b>DEKRA Certification B.V.</b> Meander 1051, 6825 MJ Arnhem PO. Box 5185, 6802 ED Arnhem The Netherlands T +31 88 96 83000 • F +31 88 96 83100 www.dekra-certification.com
NOTES: I Undertake that all data and information provided are genuine and accurate			

CONFIRMATION OF COMPLIANCE IS BASED UPON:

- ENEC CERTIFICATE 2180577.03 ISSUED BY DEKRA CERTIFICATION B.V.
- IECEE TEST REPORT 2180577.53 ISSUED BY DEKRA CERTIFICATION B.V.