


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Luminaire for emergency lighting with LED light source
Name and address of the applicant	COOPER SECURITE SAS Rue Beethoven 63204 Riom France
Name and address of the manufacturer	Cooper Csa S.r.l. Via San Bovio,3 – Edificio Y 20090 Segrate (MI) Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Digital Lighting (Dongguan) Company Ltd Xinmin District, Chang'an Town , Dongguan City, Guangdong Province 523879 China
<i>Note: When more than one factory, please report on page 2</i>	
Ratings and principal characteristics	STD2-8 LUM10244 230 V, 50/60 Hz, LED module, Class II; IP42, ta 5 – 40 °C Maintained, 8 Lumen, battery NiCd 3,6 V 0,8 Ah 300 minutes. Type installation: ceiling / wall / recessed ceiling STD2-8ES LUM10246 230 V, 50/60 Hz, LED module, Class II; IP65. ta 5 – 40 °C Maintained, 8 Lumen, battery NiCd 3,6 V 0,8 Ah 300 minutes. Type installation: ceiling / wall / recessed ceiling
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	STD2-8 LUM10244, STD2-8ES LUM10246
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 The luminaire can be mounted on the recessed ceiling by the means of accessory code SL2RB
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-2-22:2014 National differences: EU Group Differences 3505173.50
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

Meander 1051, NL-6825 MJ Arnhem, Netherlands
DEKRA Certification B.V.