

# CERTIFICATE

Issued to:  
Applicant:  
**EATON; CEAG Notlichtsysteme GmbH**  
**Senator-Schwartz-Ring 26**  
**59494 Soest, Germany**

Licensee:  
**EATON; CEAG Notlichtsysteme GmbH**  
**Senator-Schwartz-Ring 26**  
**59494 Soest, Germany**

Product : Luminaire for emergency lighting with LED light source  
Trade name(s) : EATON, EATON CEAG, EATON Crompton, EATON JSB or EATON MENVIER  
Type(s)/model(s) : 3503.1 LED CG-S, 3504.1 LED CG-S, 3514 LED CG-S and 3604.1 LED CG-S

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60598-1:2015, EN 60598-1:2015/A1:2018, EN 60598-2-22:2014 and EN 60598-2-22:2014/A1:2020
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 990758


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 3 September 2020 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 88-115485

DEKRA Certification B.V.



B.T.M. Holtus  
Managing Director



C. Nitschke  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	: Luminaire for emergency lighting with LED light source
Trade name(s)	: EATON, EATON CEAG, EATON Crompton, EATON JSB or EATON MENVIER
Type(s)/model(s)	: 3503.1 LED CG-S, 3504.1 LED CG-S, 3514 LED CG-S and 3604.1 LED CG-S
Rated voltage and frequency	: 220-240Vac; 50/60Hz; 176-275Vdc
Degree of protection	: IP20
Ambient temperature (ta)	: -20°C...40°C
Description	: Centrally supplied luminaire for emergency lighting with LED light source

**Product data – type 3503.1 LED CG-S**

Class	: II
Rated input power	: 4,4W
Description	: Round safety luminaire for recessed mounting with HighPower LEDs 3 x 1W

**Product data – type 3504.1 LED CG-S**

Class	: II
Rated input power	: 5,8W
Description	: Round safety luminaire for recessed mounting with HighPower LEDs 4 x 1W

**Product data – type 3514 LED CG-S**

Class	: I
Rated input power	: 5,8W
Description	: Round safety luminaire for surface ceiling mounting with HighPower LEDs 4 x 1 W

**Product data – type 3604.1 LED CG-S**

Class	: II
Rated input power	: 5,8W
Description	: Quadratic safety luminaire for recessed mounting with HighPower LEDs 4 x 1W

**TESTS****Test requirements**

EN 60598-1:2015  
EN 60598-1:2015/A1:2018  
EN 60598-2-22:2014  
EN 60598-2-22:2014/A1:2020

**Test result**

The test results are laid down in DEKRA test file 341959800.

**Additional information**

This certificate replaces certificate No. 2181270.01 which we hereby declare invalid.

The list of components is laid down at test report 3419598.50.

**Conclusion**

The examination proved that all requirements were met.

**Factory locations**

EATON; CEAG Notlichtsysteme GmbH  
Senator-Schwartz-Ring 26  
59494 Soest, Germany

SC Cooper Industries Romania SRL  
Zona Industrială Vest Str. III, Nr. 12  
310510 Arad, Romania