

CERTIFICATE

Issued to:
Applicant:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Licensee:
EATON; CEAG Notlichtsysteme GmbH
Senator-Schwartz-Ring 26
59494 Soest, Germany

Product : Electronic LED Driver
Trade name(s) : EATON, EATON CEAG, EATON JSB or EATON Menvier
Type(s)/model(s) : V-CG-SLDXC 28.1 and V-CG-SLDX 28.1

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61347-1:2015, EN 61347-2-13:2014, EN 61347-2-13:2014/A1:2017, EN 62384:2006 and EN 62384:2006/A1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 990758


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration of the ENEC certification agreement and under the conditions of the ENEC certification agreement.

This certificate is issued on 16 September 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-109479

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



A.C. Slingerland
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Electronic LED Driver
Trade name(s)	: EATON, EATON CEAG, EATON JSB or EATON Menvier
Type(s)/model(s)	: V-CG-SLDXC 28.1 and V-CG-SLDX 28.1
Rated voltage / nature of supply	: 176-275 Vdc, 220-240 Vac
Rated frequency	: 50/60 Hz
Rated input current	: 0,025 Adc, 0,037 Aac
Power factor	: pf : 0,52...0,62
Rated Wattage	: 3,5 W
Output voltage	: 28 Vdc
Output current	: 0,125 Adc
Max. case temperature	: tc = 70 °C max
Ambient temperature range	: ta=-20 ... +50 °C
Degree of protection	: IP20
Description	: Suitable for built-in into centrally supplied emergency luminaires

TESTS**Test requirements**

EN 61347-1:2015
EN 61347-2-13:2014
EN 61347-2-13:2014/A1:2017
EN 62384:2006
EN 62384:2006/A1:2009

Test result

The test results are laid down in DEKRA test file 223633600.

Additional information

The list of components is laid down at test report 2236336.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

Tectron GmbH
Querstrasse 2
37339 Worbis, Germany

Tonfunk GmbH Ermsleben
Anger 20
06463 Falkenstein/harz, Germany